



RURAL DRINKING WATER & SANITATION DEPARTMENT, Gok Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.

NABL Accredited Laboratory Bangalore urban

		TEST	REPORT		
Address of the sampling location :- INNOVATIVE INTERNATIONAL				Report date: 25/04/2025	
PUBLIC SCHOOL			Report Number: 0011		
			Reference: TRF •		
Ramasandra, Sulikere Post, Kengeri Hobli,			Sample code: 0011		
Bengaluru-560060.				Date of Sample collection: 23/04/2025	
				Analysis start date: 24/04/2025	
				Analysis completion date: 24/04/2025	
				Sample quantity: 1 Liter	
ampl	le Particulars: R.O water				1
SI. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Desc	ription: Colourless liquid				•
1	pH Value @25°C Temp	7.1	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, μS/cm @25°C Temp	150			IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	<1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	90	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO ₃ , mg/I	42.0	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO ₃ , mg/l	40.4	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	8.1	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	5.0	30	100	IS 3025 (Part-46) : 2023
11	Chloride as CI, mg/I	13.2	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO ₄ , mg/l	6.6	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	Nil	1	1.5	APHA 24 th Edition
14	Nitrate as NO ₃ , mg/l	11.8	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/I mark: The above given sample conf	Nil	1	No relaxation	IS 3025 (Part-53) : 2003

specifications for the above mentioned

Analysed by: Megha Kis Senior Analyst/Junior Analyst

BENGALURI URBAN

Authorized Signatory(Technical Manager: Pavithra B.S

RDWSD/WQMSP/TeR/01

Note:

- The above results relate only to the sample tested.
- The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.

---END---

- Samples will be discarded after 15 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01