

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 29

Date: 12-05-2025

It is certified that an inspection team headed by **DR Uma U G MEDICAL OFFICER**, from **PRIMARY HELATH CENTER , SULIKERE VILLAGE , KENGERI HOBLI, BANGALORE -560060** inspected the **INNOVATIVE INTERNATIONAL PUBLIC SCHOOL , RAMASANDAR SULIKERE POST KENGERI HOBLI BANGALORE -560060** on **12-06-2025** and on the basis of Water Test Report (Attached) bearing **No. 0011/2025-26** dated **25-04-2025** of **RURAL DRINKING WATER AND SANITATION DEPARTMENT GOK (PHED Lab)& No.RDWSD/WQMSP/TeR /01** dated **25-04-2025** of **BENGALRU URBAN DIVISIONAL LABARATORY BANASHANKRI ,BANGALORE-560070** certified that the **INNOVATIVE INTERNATIONAL PUBLIC SCHOOL** has safe drinking water facilities for the students and members of staff of the institution . School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /State /U.T . Govt .

This certificate is valid till ONE YEAR.

Signature with Seal

Name: **DR Uma U G**

Designation: **MEDICAL OFFICER**

Name & Address of the Office

/Department:

**PRIMARY HEALTH CENTER, SULIKERE
VILLAGE, KENGERI HOBLI BANGALORE
SOUTH THALUK BANGALORE -560060**

To,

INNOVATIVE INTERNATIONAL PUBLIC SCHOOOL

RAMASANDRA. SULIKERE POST KENEGERI HOBLI,


BANGALORE -560060

Note: The certificates is to be issued by authorized officer /PHED Lab / local bodies



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT					
Address of the sampling location :- INNOVATIVE INTERNATIONAL PUBLIC SCHOOL Ramasandra, Sulikere Post, Kengeri Hobli, Bengaluru-560060.				Report date: 25/04/2025	
				Report Number: 0011	
				Reference: TRF.	
				Sample code: 0011	
				Date of Sample collection: 23/04/2025	
				Analysis start date: 24/04/2025	
				Analysis completion date: 24/04/2025	
				Sample quantity: 1 Liter	
Sample Particulars: R.O water					
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	7.1	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C Temp	150	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	<1.0	5	15	IS 3025 (Part-4) : 2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	90	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO_3 , mg/l	42.0	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO_3 , mg/l	40.4	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	8.1	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	5.0	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	13.2	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO_4 , mg/l	6.6	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	Nil	1	1.5	APHA 24 th Edition
14	Nitrate as NO_3 , mg/l	11.8	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: Megha K.S Senior Analyst/Junior Analyst			Authorized Signatory: Pavithra B.S Technical Manager: Pavithra B.S		



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---